



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA181244

**Certificate Holder:** Zhejiang Benyi Electrical Co., Ltd.  
Wenzhou Bridge Industrial Zone,  
Beibaixiang, Yueqing,  
Zhejiang 325603  
P.R. China

**Class Description:** Non-Declared  
**Product Description:** DC Circuit Breaker

**Brand Name:**



**Model No.:**

BDM-125

**Markings:**

500Vdc 65, 80, 100, 125A

Uimp=8kV,

Ui=500Vdc

Ii=5In

Ics=Icu=15kA

IP66, Cat A, 40°C

**Standard:**

AS/NZS IEC 60947.2:2015

AS/NZS IEC 60947.1:2015

**Conditions:**

Nil

**Certification Mark:** SAA181244 or RCM

**Date First Registered:** 18 June 2018

**Date of Expiry:** 18 June 2023


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 18-06-18 181244/1



APPROVALS®

## Certificate of Suitability

\*Addendum\*

**Certificate No.:** SAA181244

**Date of Issue:** 18 June 2018

**Class Description:** Non-Declared  
**Product Description:** DC Circuit Breaker

**Additional Models**

BDM-250

**Description**

500Vdc 125, 160, 200, 225, 250A  
Uimp=8kV,  
Ui=500Vdc  
Ii=5In  
Icu=Ics=15kA


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 18-06-18 181244/2



A P P R O V A L S ®

## Certificate of Suitability

\*Addendum\*

**Certificate No.:** SAA181244

**Date of Issue:** 20 November 2020

**Regulatory Definition:** Non-Declared  
**Product Description:** DC Circuit Breaker

**General Modification:**

Updated IP rating from IP66 to IP66NW.


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 20-11-20 181244/3